



BDS-256 / DCM-480 MOUNTING WARNING

The following note has been added to the DCM-480 General Assembly drawing BDS-168-B586:

WARNING: Mounting screws on the bottom of the box cannot exceed 0.125" (1/8") depth into the DCM enclosure.

Please add this note to your drawing.

When mounting the enclosure, you must be certain that the screw does not go into the bottom of the housing by more than 1/8". Screws that go more than 1/8" into the housing will electrically or mechanically damage the unit.

This notice applies only to the rectangular ("shoebox") model and not to the rack mount model currently being produced. The "shoebox" model is no longer in production.

For more information, contact Albercorp.

Alber Corp.
990 South Rogers Circle, Suite 11
Boca Raton, FL 33487
Tel: 561-997-2299 Fax: 561-997-5588
www.alber.com / e-mail: alber@alber.com